




ScanVolt 03

Rubber Insulating Electrical Gloves

Features

- CE category III
- Protects against high voltages and electrical hazards
- Max. use voltage: 7.500V. AC, RMS
- Highly flexible and comfortable to wear
- 100% latex
- Sales quantity: 1 pair
- QR technology to view A.C. dielectric test report and product specifications

Please note that ScanVolt 03 must be tested every 12 months after manufacturing date when unused. After opening the ScanVolt 03 must be tested every 6 months. Due to stock regulation, it may occur that testing must be carried out immediately upon receipt.

Recommended Pneumatic Glove Tester for compulsory air inflation test also available.

The periodic dielectric test can be conducted on request at accredited test institutes (e.g., Eurthco, United Kingdom)

Certification

CE Certified
 EN 420:2003+A1:2009 (general requirements)
 EN 60903:2003 (Class 1) (electrical-resistant)
 IEC 60903:2014 (electrical-resistant)

Available sizes

One size

Available colours



High Viz
Orange

